

4  
5 DIRECT TESTIMONY OF  
6 EUGENE L. SHLATZ  
7 ON BEHALF OF NORTHWESTERN ENERGY  
8

9 TABLE OF CONTENTS

10	<u>Description</u>	<u>Starting Page No.</u>
11	Witness Information	2
12	Purpose and Summary of Testimony	4
13	Overview of Regulation and Frequency Response Service	8
14	Analysis Results	9
15	Methodology for Regulation and Frequency Response Service	13
16	Allocation of Regulation and Frequency Response Service to	
17	Wholesale Customer Classes	19
18	Flex Reserves Service	22
19	Conclusion	24
20	Verification	25
21		
22	<u>Exhibits</u>	
23	Resume of Eugene L. Shlatz	Exhibit ELS-1
24	Load Variability Study and Flex Reserves Analysis	Exhibit ELS-2

2

3

**Witness Information**

4 **Q. Please identify yourself, your employer, and your job title.**

5 **A.** My name is Eugene L. Shlatz. I have been employed by Green Mountain  
6 Solutions Consulting, Inc. (“GMS”) since 2022. My business address is 70  
7 South Winooski Avenue, Burlington, Vermont.

8

9 **Q. On whose behalf are you testifying?**

10 **A.** I am appearing on behalf of NorthWestern Corporation d/b/a NorthWestern  
11 Energy (“NorthWestern”).

12

13 **Q. Please summarize your education and experience.**

14 **A.** I have more than 40 years’ experience in electric utility operations,  
15 engineering, and electric pricing. At GMS, I manage engagements for electric  
16 utility system reliability, renewable energy, and advanced energy systems. I  
17 have supported filings before federal, state, and Canadian Provincial  
18 regulatory commissions on a range of electric utility matters, including  
19 renewables integration, net metering, and retail and wholesale rates. Prior to  
20 my employment at GMS, I was employed by Guidehouse Inc. (previously  
21 Navigant Consulting, Inc.) for 23 years.

22

1 I hold Bachelor's and Master's degrees in Electric Power Engineering from  
2 Rensselaer Polytechnic Institute and am a registered Professional Engineer  
3 in Vermont, specializing in electrical engineering. I am a Life Member of the  
4 Institute of Electrical and Electronics Engineers (IEEE) and previously was a  
5 Section Chair in the State of Vermont. I have managed technical and  
6 economic studies of electric supply and reliability for municipal, cooperative,  
7 and investor-owned electric utilities throughout North America.

8  
9 My experience includes evaluation of conventional and renewable energy  
10 sources, and the impact of these sources on electric reliability and cost of  
11 supply. I have testified before state utility commissions on electric reliability,  
12 renewable energy, and siting of energy delivery facilities on behalf of  
13 municipal, cooperative, and investor-owned utilities, including rate cases  
14 involving the review of capital projects proposed for inclusion in rates. I also  
15 was employed by Green Mountain Power ("Company") in various positions of  
16 increasing responsibility, including Director of Engineering and Operations,  
17 where I was responsible for the planning, design, and operation of the  
18 Company's generation, transmission, and distribution systems. My  
19 qualifications and previous appearances before regulatory agencies appear in  
20 more detail in Exhibit ELS-1.

21  
22 As a matter of practice, GMS is committed to maintaining an independent and  
23 unbiased approach to its engagements.

1 **Q. Have you previously testified before the Montana Public Service**  
2 **Commission (“MPSC”)?**

3 **A.** Yes, I testified as an expert witness on behalf of NorthWestern before the  
4 MPSC in its 2018 electric general rate review under Docket No. 2018.02.012.  
5 My testimony supported NorthWestern’s proposed net metering tariff and  
6 rates.

7  
8 **Q. Have you previously testified before the Federal Energy Regulatory**  
9 **Commission (“FERC”) on Transmission Open Access?**

10 **A.** Yes, I prepared direct testimony and appeared as an expert witness in  
11 support of NorthWestern’s 2019 Open Access Transmission Tariff (“OATT”)  
12 filing before FERC in ER19-1756-000. I have also testified on behalf of Duke  
13 Energy Florida, El Paso Electric, Public Service of New Mexico, and Northern  
14 Indiana Public Service in their OATT filings before FERC.

15  
16 **Purpose and Summary of Testimony**

17 **Q. What is the purpose and scope of your testimony?**

18 **A.** My testimony presents the results of the updated analysis I performed to  
19 determine generation reserve requirements under NorthWestern’s OATT  
20 Schedules 3, 3A, and 11 for the period January 1 through December 31,  
21 2023. The analysis I present here is an update consistent with the study  
22 presented in NorthWestern’s 2019 FERC filing in ER19-1756-000 (“2019  
23 Study”). To support the updated analysis, I also updated the Load Variability

1 (“LV”) study completed by Navigant Consulting, Inc. in 2019 that  
2 NorthWestern relied upon to support generating reserve requirements  
3 associated with these three schedules at that time. I applied the results  
4 contained in the updated LV study conducted by GMS in June 2024 to  
5 support the updated reserve requirements calculations for these three  
6 schedules. The updated LV study was prepared under my direction for  
7 NorthWestern and is provided as Exhibit ELS-2. This analysis documents the  
8 amount of generation capacity that NorthWestern must reserve for customers  
9 receiving Regulation and Frequency Response Service under Schedules 3  
10 and 3A of NorthWestern’s OATT and Flex Reserves Service under Schedule  
11 11. Regulation and Frequency Response Service includes two ancillary rate  
12 components: (1) Fast-Moving and (2) Load Following reserves.

13  
14 My testimony also describes how GMS allocated generating capacity that  
15 NorthWestern reserves for Regulation and Frequency Response Service to  
16 four wholesale customer classes, which includes Variable Energy Resource  
17 (“VER”) and non-VER resources. The VER resources include wind and solar  
18 generation; hereafter referred to as Wind and Solar. The four wholesale  
19 customer classes that generation reserves are assigned include: (1) Load, (2)  
20 Wind, (3) Solar, and (4) Non-VER Generators. GMS used a test year of  
21 January 2023 through December 2023 to quantify and allocate generating  
22 capacity reserves to wholesale customer classes receiving Regulation and  
23 Frequency Response Service. The generating units assigned to provide

1 regulating services are supported in the Direct Testimony of Joseph M.  
2 Stimatz.

3

4 NorthWestern is also updating the analysis of reserve requirements for Flex  
5 Reserves Service under Schedule 11 of its OATT that applies to wind  
6 generators receiving wholesale service within its Montana service territory.  
7 Flex Reserves is the additional generating capacity NorthWestern reserves to  
8 respond to downward ramps in wind generator output for units located within  
9 its Balancing Authority Area (“BAA”). Because NorthWestern requires Flex  
10 Reserves to meet downward ramps in output from wind generators, this  
11 service applies only to the wind generators.<sup>1</sup>

12

13 **Q. What has changed between the time NorthWestern submitted its 2019**  
14 **OATT filing before FERC and your updated analysis using 2023 data?**

15 **A.** The primary change is the addition of a fourth customer class, Solar, which  
16 NorthWestern now includes in Schedules 3 and 3A to account for the large  
17 amount of solar generation installed in its BAA following NorthWestern’s 2019  
18 OATT filing. Approximately 160 megawatts (“MW”) of large solar generating  
19 plants have been installed over the past two years; one is the 80-MW MTSUN  
20 generation plant that became operational in January 2023, and the second is  
21 the 80-MW Apex solar plant that became operational in August 2023. An

---

<sup>1</sup> NorthWestern also uses its OATT ancillary services rates to determine avoided costs for ancillary services for wind Qualifying Facilities on its Montana system.

1 additional 17 MW of smaller solar generating plants raises the total installed  
2 solar capacity in service in 2023 to 177 MW.

3

4 The second material difference is the installation of approximately 200 MW of  
5 wind generation in NorthWestern's BAA, which raises the total installed wind  
6 generation to 440 MW.

7

8 **Q. How is your testimony organized?**

9 **A.** My testimony provides as follows:

- 10 • First, I summarize the results of GMS's analysis regarding LV and Flex  
11 Reserves and explain how I used these results to determine the amount of  
12 generating capacity NorthWestern must reserve for customers that receive  
13 Regulation and Frequency Response and Flex Reserves Services.
- 14 • Next, I describe the methods GMS applied to determine the amount of  
15 Regulation and Frequency Response Service that NorthWestern must  
16 provide to comply with NERC's current reliability standard. The Regulation  
17 and Frequency Response Service includes two delivery components: (1)  
18 Fast-Moving and (2) Load Following reserves.
- 19 • Next, I present the allocation of Fast-Moving and Load Following reserves  
20 to four customer classes: (1) Load; (2) Wind, (3) Solar, and (4) Non-VER  
21 Generators. GMS applied the Fair Allocation methodology consistent with  
22 the 2019 Study and that FERC has accepted in prior wholesale

1 applications to allocate Fast-Moving and Load Following reserves to each  
2 customer class.

- 3 • Lastly, I present the results of the Flex Reserves segment of our analysis  
4 and the amount of generating capacity that NorthWestern must reserve to  
5 respond to downward ramps of wind generators located within its Montana  
6 BAA.

### 8 **Overview of Regulation and Frequency Response Service**

#### 9 **Q. What is Regulation and Frequency Response Service?**

10 **A.** Regulation and Frequency Response Service is an ancillary service required  
11 for transmission service under the NorthWestern OATT and is reflected in  
12 Schedules 3 and 3A of the OATT. This service is necessary to provide for the  
13 continuous balancing of resources (generation and interchange) with load and  
14 for maintaining scheduled interconnection frequency at sixty cycles per  
15 second (60 Hz). In discussing Regulation and Frequency Response Service  
16 in Order No. 888, where FERC first made provision of this service mandatory  
17 for public utilities, FERC explained that “someone must supply extra  
18 generating capacity, called regulating margin, and provide a controlled  
19 dispatch of that capacity to balance the moment-to-moment variations in the  
20 load located in a control area.”<sup>2</sup> In addition to meeting the moment-to-

---

<sup>2</sup> *Promoting Wholesale Competition Through Open Access Nondiscriminatory Transmission Services by Public Utilities and Recovery of Stranded Costs by Public Utilities and Transmitting Utilities*, 61 Fed. Reg. 21,540 (1996), FERC Stats. & Regs. ¶ 31,036 at 31,960 (1996) (Order No. 888), *order on reh'g*, Order No. 888-A, 62 Fed. Reg. 12,274 (1997), FERC Stats. & Regs. ¶ 31,048 (1997), *order on reh'g*, Order No. 888-B, 62 Fed. Reg.



1 moment fluctuations in load, FERC has explained that Regulation and  
2 Frequency Response Service provides the capacity necessary for balancing  
3 within-the-hour variations in load.<sup>3</sup>  
4

### 5 **Analysis Results**

6 **Q. What findings and conclusions did GMS reach regarding its analysis in**  
7 **this case?**

8 **A.** A summary of GMS's findings and conclusions follows:

- 9 • NorthWestern maintains data and records that I relied upon to accurately  
10 determine the amount of generating capacity it must reserve for  
11 transmission customers receiving Regulation and Frequency Response  
12 Service under NorthWestern's OATT. Consistent with the 2019 Study,  
13 GMS used one-minute interval data to determine the amount of generating  
14 capacity that NorthWestern must have online or readily available to  
15 comply with NERC's reliability standard.

---

64,688, 81 FERC ¶ 61,248 (1997), *order on reh'g*, Order No. 888-C, 82 FERC ¶ 61,046 (1998), *aff'd in relevant part sub nom. Transmission Access Policy Study Group, et al. v. FERC*, 225 F.3d 667 (D.C. Cir. 2000), *aff'd sub nom., New York v. FERC*, 535 U.S. 1 (2002).

<sup>3</sup> *Allegheny Power Service Corp.*, 85 FERC ¶ 61,275 at 62,120 (1998) (“[L]oad following must be available at all times both to cover the moment-to-moment load fluctuations and to match resources (including those which may be block scheduled) to load throughout the hour. . .”); *Kentucky Utilities Co.*, 85 FERC ¶ 61,274 at 62,108 (1998) (explaining that, through Regulation and Frequency Response Service, “utilities are required to ‘provide for the continuous balancing of resources with load,’ by which we meant not just the moment-to-moment balancing, but also any other on-going balancing of generation resources with load that might be required to maintain system reliability (e.g., the balancing needed to accommodate block schedules between control areas.”).

- 1           • For the Fast-Moving component of Regulation and Frequency Response  
2           Service, reserve requirements are equal to the maximum difference in  
3           NorthWestern’s one-minute Supervisory Control and Data Acquisition  
4           (“SCADA”) load data and the 15-minute Centered Moving Average  
5           (“CMA”) for the Load class net of non-VER Generation, Wind and Solar  
6           one minute output (i.e., Total Net Load). For the non-VER and VER  
7           Generator classes, Fast-Moving Reserves equals the maximum difference  
8           between the one-minute generator output data and 15-minute CMA of  
9           generator output.<sup>4</sup> The derivation of CMA is described in greater detail in  
10          subsequent sections of my testimony. GMS’s study confirmed that the  
11          total amount of generating capacity that NorthWestern must reserve for  
12          Fast-Moving Reserves is 37.2 MW.
- 13
- 14          • For the Load Following component of Regulation and Frequency  
15          Response Service, reserve requirements are derived based on the  
16          maximum difference in CMA values within a 15-minute clock interval.  
17          Consistent with the 2019 Study and FERC precedent, GMS defined Load  
18          Following Reserves as the difference between the highest and lowest  
19          values for downward ramps within each 15-minute clock interval. GMS  
20          selected 15-minute clock intervals for Load Following to comply with  
21          FERC’s position and prior OATT rulings that wholesale customers must be  
22          allowed to schedule generation on a 15-minute basis. My analysis using

---

<sup>4</sup> Because generators produce electric output, the signs are reversed to account for the fact that when generator output ramps upward, net load decreases and vice-versa when generator output ramps downward.

1 the 2023 data determined that the total amount of generating capacity that  
2 NorthWestern must reserve for Load Following Reserves is 56.1 MW.

- 3
- 4 • Under rules adopted in 2016, NorthWestern is required to bring its system  
5 within Balancing Authority Area Control Error Limits (“BAAL”) within each  
6 30-minute clock interval, on a rolling basis, under NERC’s BAL-001-2  
7 reliability standard.<sup>5</sup> To comply with this requirement and avoid monetary  
8 penalties, NorthWestern must have sufficient reserves readily available to  
9 meet this limit during each 30-minute interval for all hours of the year. The  
10 current NERC standard requires 100% compliance – each and every hour.

- 11
- 12 • Consistent with the 2019 Study, a 95% dispersion interval was used in the  
13 derivation of Flex Reserves. GMS’s 2024 LV study found that the amount  
14 of generation NorthWestern must reserve to provide Flex Reserves  
15 Service to wind generators located in its BAA is 46.8 MW.

- 16
- 17 • GMS’s analysis is consistent with the 2019 Study methodology and  
18 accurately derives the amount of Fast-Moving, Load Following, and Flex  
19 Reserves that NorthWestern must have online or readily available to

---

<sup>5</sup> Under the prior NERC standard, NorthWestern was required to comply with Control Area Performance Standard (“CPS-2”), under which it had to achieve 90% compliance with the L10 Area Control Error (ACE). Under these prior rules, NERC required “Each Balancing Authority shall operate such that, on a rolling 12-month basis, the average of the clock-minute averages of the Balancing Authority’s Area Control Error (ACE) divided by 10B (B is the clock-minute average of the Balancing Authority Area’s Frequency Bias) times the corresponding clock-minute averages of the Interconnection’s Frequency Error is less than a specific limit.”

1           comply with NERC’s current reliability standard. Further, the use of the  
 2           Fair Allocation methodology approved by FERC in prior OATT rate  
 3           applications was used to allocate the reserves to each of the four  
 4           wholesale customer classes that receive Regulation and Frequency  
 5           Response Service to maintain consistency between the analyses.  
 6           According to GMS’s recent analysis, the amount of generating capacity  
 7           that NorthWestern must reserve to provide these ancillary services under  
 8           its OATT for each customer class is summarized below.

Fast Moving	Load	4.0
	Wind	9.7
	Solar	14.5
	Non-VER Generation	9.0
	<b>Total</b>	<b>37.2</b>
Load Following	Load	7.7
	Wind	23.8
	Solar	7.5
	Non-VER Generation	17.1
	<b>Total</b>	<b>56.1</b>
Flex Reserves	<b>Wind</b>	<b>46.8</b>
<b>Total</b>		<b>140.1</b>

9   **Q.   How do the results of the updated study compare to the 2019 Study?**

10 **A.**   The total amount of required reserves for the Fast-Moving and Load  
 11   Following components of Regulation and Frequency Response Service has  
 12   increased by 7% and 20%, respectively, as presented in the table below. Flex  
 13   Reserves Service requirements have decreased by 11% between the two  
 14   studies.

<b>Reserve Requirement</b>	<b>2023 Results (MW)</b>	<b>2019 Results (MW)</b>
Fast Moving	37.2	34.8
Load Following	56.1	46.8
Flex Reserves	46.8	52.5
<b>Total</b>	<b>140.1</b>	<b>134.1</b>

1                    **Methodology for Regulation and Frequency Response**

2    **Service**

3    **Q.    What are the two components of Regulation and Frequency Response**  
4    **Service?**

5    **A.**    Regulation and Frequency Response Service is the amount of generating  
6            capacity NorthWestern must reserve to (1) respond to “moment-to-moment  
7            fluctuations in load” or “Fast-Moving Reserves” and (2) the capacity  
8            necessary for the on-going balancing of generation resources with load or  
9            “Following Reserves.” I have calculated NorthWestern’s generation reserve  
10          requirements for Regulation and Frequency Response Service consistent  
11          with the approach used in 2019 to derive Fast-Moving and Following  
12          reserves, including use of a 15-minute CMA.

13

14   **Q.    Please describe the methodology GMS used to derive the Fast-Moving**  
15   **and Load Following components of Regulation and Frequency**  
16   **Response Service.**

17   **A.**    First, I explain the method GMS used to calculate the amount of generating  
18          capacity that NorthWestern must reserve for the Fast-Moving component,  
19          followed by the methodology we applied to derive Load Following reserves.

1 At the outset, I note that, consistent with the 2019 Study, GMS used a 15-  
2 minute CMA to measure the deviations for which NorthWestern must hold  
3 reserves.

4

#### 5 Fast-Moving Reserves

6 Consistent with the 2019 Study, GMS obtained one-minute SCADA data for  
7 load, and VER and non-VER generator output data from NorthWestern, and  
8 used this data to derive values for Total Net Load,<sup>6</sup> and for the Load, Wind,  
9 Solar, and Non-VER Generation components for the January 1, 2023 through  
10 December 31, 2023 test year within its service territory.<sup>7</sup> GMS then calculated  
11 the 15-minute CMA for each one-minute interval over the test year. The  
12 resulting data set contains approximately 525,000 one-minute and 35,000 15-  
13 minute CMA interval readings for each customer class.

14

15 Next, for each one-minute interval, GMS compared the one-minute reading to  
16 the 15-minute CMA for each minute over the entire test year. The difference  
17 between the one-minute interval data and the 15-minute CMA is the amount  
18 of Fast-Moving generation that NorthWestern must supply to respond to rapid  
19 changes in load or generator output.<sup>8</sup> The following chart provides two


---

<sup>6</sup> Total Net Load is the difference between total BAA load minus wind, solar and non-generation output.

<sup>7</sup> References to NorthWestern's service territory and BAA are used interchangeably. Both represent the same amount of load and customers that receive OATT service from NorthWestern.

<sup>8</sup> The 15-minute CMA trend represents the Load Following component, whereas the minute-by-minute difference is the amount of Fast-Moving generation needed to respond to variable load and generating output.


1 examples of this calculation using a randomly selected date. In the following  
2 excerpt of NorthWestern’s load data on June 19, 2023, the solid line  
3 represents the minute-by-minute load in NorthWestern’s Montana service  
4 territory while the dashed line is the 15-minute CMA. The difference between  
5 the one-minute load of 1,328 MW minus the 15-minute CMA of 1,333 MW at  
6 8:41 pm on June 19, 2023 is 5 MW; that is, the point where the downward  
7 ramp intersects the 15-minute CMA at 8:41 pm. The Fast-Moving Reserve  
8 requirement at this time is 5 MW. Similarly, the Fast-Moving value at 9:03 pm  
9 is the difference between the 15-minute CMA of 1,325 MW and the one-  
10 minute load of 1,317 MW, or -8 MW.



11 The process described above is repeated for each one-minute interval over the  
12 entire test year, with the one-minute difference in each interval sorted from  
13 maximum to lowest value. The difference between the highest value and the lowest  
14 value over the 99% dispersion interval is the amount of generating capacity  
15 assigned to Fast-Moving Reserves.

1  
2  
3  
4  
5  
6  
7  
8  
9

The following chart presents the one-minute differences for Total Net Load for the test year. The absolute values that appear at the intersection of the 0.5 and 99.5 percentiles, or 99% after the largest absolute values are removed, are then added to produce the Fast-Moving Reserve component. This methodology is consistent with the 2019 Study. According to GMS's analysis, the total amount of generating capacity that NorthWestern must reserve for the Fast-Moving component is 37.2 MW. The allocation of the 37.2 MW of Fast-Moving Reserves between the Load, VER, and Non-VER classes is discussed later in my testimony.



10  
11  
12  
13

### Load Following Reserves

For Load Following, GMS followed a process similar to the methodology it used to calculate Fast-Moving Reserves. GMS applied the same one-minute load and generator output data for Total Net Load, Load, VER, and non-VER




1 wholesale customer classes used to derive Fast-Moving Reserves to  
2 calculate the 15-minute CMA for each minute over the test year.<sup>9</sup>  
3 The resulting data set contains approximately 525,000 15-minute CMA  
4 interval readings. The maximum difference between 15-minute CMA values  
5 within each 15-minute clock interval is the amount of generation that  
6 NorthWestern must reserve for the Load Following component of Frequency  
7 and Regulating Reserve Service.

8  
9 The following chart provides two examples of the Load Following calculation on the  
10 same day and time that appears in the Fast-Moving chart above. Load Following  
11 Reserves are derived for each consecutive 15-minute clock interval on the chart.  
12 The Load Following component for each interval is equal to the difference between  
13 the highest and lowest 15-minute CMA within the interval, but only for upward ramps  
14 when NorthWestern generating resources must increase output to make up the  
15 deficit. (The solid line representing the minute-by-minute load in NorthWestern's  
16 Montana service territory is shown for illustration purposes only.)

---

<sup>9</sup> Non-VER generation is excluded as it includes the generators that provide Load Following. The non-VER generators maintain energy balances, with output that changes in the opposite direction of changes in load or VER output.



1 In the chart, the highest load at the beginning of the 15-minute interval beginning at  
 2 8:45 pm is 1,327 MW; the lowest is 1,322 MW during the interval (note that the  
 3 highest and lowest values do not always occur at the beginning and end points of  
 4 the 15-minute clock interval). In this example, the difference in the highest and  
 5 lowest MW value is -5 MW. The Load Following component is derived only during  
 6 intervals when upward ramping occurs during each 15-minute interval; consistent  
 7 with the 2019 Study. Accordingly, the 5 MW downward ramp is excluded from the  
 8 Load Following calculation.


9  
 10 The reserve requirement is 6 MW for the 15-minute interval ending on 9:15 pm in  
 11 this example. In this instance, the highest and lowest measurements occur at the  
 12 endpoints of the interval.

13  
 14 The process described above is repeated for each 15-minute clock interval over the  
 15 entire test year, with the maximum difference for each interval sorted from maximum

1 to lowest value. The value at the 99.5% dispersion interval is the amount of  
2 generating capacity assigned to Load Following Reserves.

3

4 The following chart presents the 15-minute differences for total net load and the four  
5 wholesale customer classes. Similar to Fast-Moving Reserves, the values that  
6 appear at the intersection of the 0.5 and 99.5 percentiles appear in the chart;  
7 however, the Load Following Reserve component is derived only for upward ramps  
8 (i.e., 99.5% dispersion interval). Thus, GMS's analysis results in a value of 56.1 MW  
9 for Load Following Reserves.



10 **Allocation of Regulation and Frequency Response Service to**

11 **Wholesale Customer Classes**

12 **Q. Please describe the four wholesale customer classes evaluated in GMS's**  
13 **analysis and explain why GMS selected them.**

1 **A.** GMS allocated generating reserves that NorthWestern uses to provide for  
2 Regulation and Frequency Response Service to four customer classes: (1)  
3 Load, which includes all load, including non-NorthWestern load such as rural  
4 electric cooperatives, within NorthWestern’s BAA; (2) Non-VER generation,  
5 which includes generation located within NorthWestern’s BAA exclusive of  
6 wind and solar, (3) wind generators, and (4) solar generators located and  
7 operating within NorthWestern’s BAA during the test year. The solar customer  
8 class is a new customer class that was not included in the 2019 Study.

9  
10 The Load class includes all Non-Choice retail (NorthWestern’s bundled retail  
11 customers) and Choice retail customers including cooperatives that receive service  
12 under NorthWestern’s Montana retail and wholesale electric tariffs.

13 The non-VER class includes all generators other than VERs that are  
14 electrically located within NorthWestern’s BAA. The Non-VER class requires  
15 Fast-Moving Reserve service to account for unexpected changes in output or  
16 generator contingencies. Similar to the 2019 LV study, the Non-VER class is  
17 comprised of generators that do not provide Fast-Moving Reserve service;  
18 that is, output from generators that are not on Automatic Generation Control  
19 (“AGC”) were excluded from the minute-by-minute and CMA calculations as  
20 these units respond to instantaneous changes in BAA net load to maintain  
21 frequency within NERC requirements.

22

1 The VER customer class is comprised solely of wind and solar generators  
 2 located within NorthWestern’s BAA. The output from these generators is  
 3 highly variable and, as a class, requires Fast-Moving and Load Following  
 4 Reserves services.

5

6 **Q. Please describe GMS’s approach for allocating Regulation and**  
 7 **Frequency Response Service to NorthWestern’s four wholesale**  
 8 **customer classes.**

9 **A.** The methodology GMS followed is consistent with the 2019 Study. This  
 10 approach, referred to as the Fair Allocation methodology for regulating  
 11 reserves, offers an analytically rigorous and consistent method to allocate the  
 12 Fast-Moving and Load Following components of Regulation and Frequency  
 13 Response Service.

14

15 The following table summarizes the results of GMS’s use of the Fair  
 16 Allocation methodology to derive the Fast-Moving and Load Following  
 17 components for the current analysis.


<b>Reserve Requirement</b>	<b>Customer Class</b>	<b>Allocation (MW)</b>
Fast Moving	Load	4.0
	Wind	9.7
	Solar	14.5
	Non-VER Generation	9.0
	<b>Total</b>	<b>37.2</b>
Load Following	Load	7.7
	Wind	23.8
	Solar	7.5
	Non-VER Generation	17.1
	<b>Total</b>	<b>56.1</b>

1 **Flex Reserves Service**

2 **Q. Please describe the methodology GMS used to derive the values used**  
3 **to support Schedule 11 in NorthWestern’s OATT.**


4 **A.** Like other utilities located within the Western Electricity Coordinating Council  
5 and other regions in the United States, NorthWestern has encountered large  
6 increases in wind generation over the past three to four years. A maximum  
7 coincident output of 440 MW was measured during the test year for wind  
8 generators within NorthWestern’s service territory (for comparison,  
9 NorthWestern’s Montana BAA peak load during the 2023 test year was just  
10 over 1,900 MW). Similar to wind generators located in other utility BAAs,  
11 those located in Montana tend to produce output that is highly variable with  
12 unpredictable patterns. The magnitude of wind ramps in NorthWestern’s  
13 Montana service territory is sizable.

14  
15 There were 342 instances during the test year where wind output dropped by  
16 over 50 MW within 30 minutes. The chart below presents the cumulative  
17 number of downward wind ramping events during the test year. Notably, there  
18 were 18 instances when wind output dropped by over 100 MW and one  
19 instance where a drop of up to 150 MW occurred within a 30-minute interval.



1 Again, NorthWestern must achieve 100% compliance with NERC’s BAL-001  
 2 reliability standard. To achieve compliance, NorthWestern must reserve  
 3 generation beyond the amount needed for Fast-Moving and Load Following  
 4 Reserves to respond to downward ramps in wind generation. The additional  
 5 amount of generation NorthWestern reserves to respond to downward wind  
 6 ramps is the Flex Reserves component.

7  
 8 Consistent with the 2019 Study, GMS obtained 30-minute downward wind  
 9 ramps for the test year and sorted these ramps from lowest to highest. The  
 10 resulting value in the recent analysis of 46.8 MW is well below the installed  
 11 wind generating capacity of 440 MW and the numerous maximum down  
 12 ramps of over 100 MW that occurred during 2023.



1

**Conclusion**

2

**Q. Please summarize GMS’s recommendations.**

3

**A.** GMS used the methodology to derive Fast-Moving Reserves, Load Following Reserves, and Flex Reserves as was used and accepted by FERC for the 2019 Study. The results of this analysis are as follows:

4

5

6

Fast-Moving Reserves: 37.2 MW

7

Load Following Reserves: 56.1 MW

8

Flex Reserves: 46.8 MW

9

10

**Q. Does this conclude your direct testimony?**

11

**A.** Yes, it does.

12

13

14



**Verification**

This Direct Testimony of Eugene L. Shlatz is true and accurate to the best of my knowledge, information, and belief.

          /s/ Eugene L. Shlatz            
Eugene L. Shlatz